



Safety & Buildings Division  
201 West Washington Avenue  
P.O. Box 2658  
Madison, WI 53701-2658

Evaluation #

200414-H  
(Replaces 200091-H)

## Wisconsin Building Products Evaluation

### Condensing Boilers:

Gasmaster Series Boilers and Water Heaters  
Gasmaster Series Instantaneous Water Heaters

**Manufacturer:** Gasmaster Industries  
15050 54a Ave. Bldg. 5  
Surrey, British Columbia V3S 8E7

**Approved Product(s):** Trade Name: **Gasmaster**  
Model Numbers: GMI 200, 300, 400, 600, 800/800L,  
1M/1ML, 1.5M/1.5ML, 2M/2ML, 4M, and 1M-LS.

**SCOPE OF EVALUATION:** This review includes the cited:  
Comm code requirements in accordance with the current  
**Wisconsin Dwelling Code (UDC); International Building  
Code (IBC); International Mechanical Code (IMC); and  
International Fuel Gas Code (IFGC).**

**TESTS:** The boilers and water heaters were tested in  
accordance with ANSI Z21.13 and Z21.10.3 Standard for Gas-  
Fired Low-Pressure Steam and Hot Water Boilers and Gas-  
Fired Storage Water Heaters. The equipment has been  
certified by CSA International.

**LIMITATIONS OF APPROVAL:** The boilers and water  
heaters shall be installed as allowed in **s. Comm 23.04** of the  
**UDC; s. IBC 302.1; ss. IMC 301, 303, and 920; s. IFGC 619,**  
their listing and the manufacturer's recommendations.

This approval will be valid through December 31, 2009, unless  
manufacturing modifications are made to the product or a re-  
examination is deemed necessary by the department. The  
product approval is applicable to projects approved under the  
current edition of the applicable codes. This approval may be  
void for project approvals made under future applicable  
editions. The Wisconsin Building Products Evaluation number  
must be provided when plans that include this product are  
submitted for review.

**DISCLAIMER:** The department is in no way endorsing or  
advertising this product. The product approval is applicable to  
projects approved under the current edition of the applicable  
codes. This approval may be void for project approvals made  
under future applicable editions. This approval addresses only  
the specified applications for the product and does not waive any  
requirement not specified in this document.

Revision Date:

Approval Date: June 23, 2004 By:

Lee E. Finley, Jr.  
Product/Material &  
Building Plan Review  
Integrated Services Bureau

200414-H.doc